

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow LIW-School #4

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 14:30

Reported:

04/02/2025 12:52

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-FB Lims Reference ID: AD13604-01 Matrix: Drinking Water Sampled: 03/16/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-KIT1L Lims Reference ID: AD13604-02 Matrix: Drinking Water Sampled: 03/16/25 09:33:00									
Metals									
Lead	1.11		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-KIT1R Lims Reference ID: AD13604-04 Matrix: Drinking Water Sampled: 03/16/25 09:33:00									
Metals									
Lead	2.43		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-KIT2 Lims Reference ID: AD13604-06 Matrix: Drinking Water Sampled: 03/16/25 09:33:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL1FL Lims Reference ID: AD13604-08 Matrix: Drinking Water Sampled: 03/16/25 09:36:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL1CL Lims Reference ID: AD13604-09 Matrix: Drinking Water Sampled: 03/16/25 09:36:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL1CR Lims Reference ID: AD13604-10 Matrix: Drinking Water Sampled: 03/16/25 09:37:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL1FR Lims Reference ID: AD13604-11 Matrix: Drinking Water Sampled: 03/16/25 09:37:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-MAIN Lims Reference ID: AD13604-12 Matrix: Drinking Water Sampled: 03/16/25 09:38:00									
Metals									
Lead	12.5		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:42	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow LIW-School #4

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 14:30

Reported:

04/02/2025 12:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-SO-01 Lims Reference ID: AD13604-13 Matrix: Drinking Water Sampled: 03/16/25 09:39:00									
Metals									
Lead	3.74		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-FAC Lims Reference ID: AD13604-15 Matrix: Drinking Water Sampled: 03/16/25 09:41:00									
Metals									
Lead	2.95		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-NURSE Lims Reference ID: AD13604-17 Matrix: Drinking Water Sampled: 03/16/25 09:44:00									
Metals									
Lead	3.47		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-08 Lims Reference ID: AD13604-19 Matrix: Drinking Water Sampled: 03/16/25 09:46:00									
Metals									
Lead	1.39		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-02 Lims Reference ID: AD13604-21 Matrix: Drinking Water Sampled: 03/16/25 09:48:00									
Metals									
Lead	3.93		1	1.00	µg/L	03/20/25 14:23	03/24/25 19:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-07 Lims Reference ID: AD13604-23 Matrix: Drinking Water Sampled: 03/16/25 09:50:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-03 Lims Reference ID: AD13604-25 Matrix: Drinking Water Sampled: 03/16/25 09:52:00									
Metals									
Lead	1.19		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-06 Lims Reference ID: AD13604-27 Matrix: Drinking Water Sampled: 03/16/25 09:54:00									
Metals									
Lead	1.53		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-04 Lims Reference ID: AD13604-29 Matrix: Drinking Water Sampled: 03/16/25 09:56:00									
Metals									
Lead	1.39		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:06	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow LIW-School #4

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 14:30

Reported:

04/02/2025 12:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-DW-05 Lims Reference ID: AD13604-31 Matrix: Drinking Water Sampled: 03/16/25 09:58:00									
Metals									
Lead	3.65		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-09 Lims Reference ID: AD13604-33 Matrix: Drinking Water Sampled: 03/16/25 10:00:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:23	03/24/25 20:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL2FR Lims Reference ID: AD13604-35 Matrix: Drinking Water Sampled: 03/16/25 10:03:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL2CR Lims Reference ID: AD13604-36 Matrix: Drinking Water Sampled: 03/16/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL2CL Lims Reference ID: AD13604-37 Matrix: Drinking Water Sampled: 03/16/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL2FL Lims Reference ID: AD13604-38 Matrix: Drinking Water Sampled: 03/16/25 10:04:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-10 Lims Reference ID: AD13604-39 Matrix: Drinking Water Sampled: 03/16/25 10:05:00									
Metals									
Lead	6.04		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-19 Lims Reference ID: AD13604-41 Matrix: Drinking Water Sampled: 03/16/25 10:07:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-18 Lims Reference ID: AD13604-43 Matrix: Drinking Water Sampled: 03/16/25 10:09:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:41	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow LIW-School #4

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 14:30

Reported:

04/02/2025 12:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-DW-12 Lims Reference ID: AD13604-45 Matrix: Drinking Water Sampled: 03/16/25 10:12:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-16 Lims Reference ID: AD13604-47 Matrix: Drinking Water Sampled: 03/16/25 10:15:00									
Metals									
Lead	1.13		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-13 Lims Reference ID: AD13604-49 Matrix: Drinking Water Sampled: 03/16/25 10:17:00									
Metals									
Lead	1.35		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-14 Lims Reference ID: AD13604-51 Matrix: Drinking Water Sampled: 03/16/25 10:20:00									
Metals									
Lead	1.06		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-15 Lims Reference ID: AD13604-53 Matrix: Drinking Water Sampled: 03/16/25 10:23:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-120 Lims Reference ID: AD13604-55 Matrix: Drinking Water Sampled: 03/16/25 10:26:00									
Metals									
Lead	2.30		1	1.00	µg/L	03/20/25 14:33	03/24/25 20:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-118 Lims Reference ID: AD13604-57 Matrix: Drinking Water Sampled: 03/16/25 10:28:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-119 Lims Reference ID: AD13604-59 Matrix: Drinking Water Sampled: 03/16/25 10:31:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-117 Lims Reference ID: AD13604-61 Matrix: Drinking Water Sampled: 03/16/25 10:34:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:05	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Winslow LIW-School #4

Customer PO:

25-1057

EMSL Sales Rep:

Justin Monturano

Received:

03/17/2025 14:30

Reported:

04/02/2025 12:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-SO-WORK Lims Reference ID: AD13604-63 Matrix: Drinking Water Sampled: 03/16/25 10:37:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-113 Lims Reference ID: AD13604-65 Matrix: Drinking Water Sampled: 03/16/25 10:40:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-110 Lims Reference ID: AD13604-67 Matrix: Drinking Water Sampled: 03/16/25 10:43:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-112 Lims Reference ID: AD13604-69 Matrix: Drinking Water Sampled: 03/16/25 10:46:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:33	03/24/25 21:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-111 Lims Reference ID: AD13604-71 Matrix: Drinking Water Sampled: 03/16/25 10:49:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 18:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-109 Lims Reference ID: AD13604-73 Matrix: Drinking Water Sampled: 03/16/25 10:52:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 18:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-107 Lims Reference ID: AD13604-75 Matrix: Drinking Water Sampled: 03/16/25 10:55:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 18:54	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-SO-108 Lims Reference ID: AD13604-77 Matrix: Drinking Water Sampled: 03/16/25 10:58:00									
Metals									
Lead	1.14		1	1.00	µg/L	03/20/25 14:37	03/24/25 18:56	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-DW-106 Lims Reference ID: AD13604-79 Matrix: Drinking Water Sampled: 03/16/25 11:01:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 18:58	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Winslow LIW-School #4

Customer PO: 25-1057
EMSL Sales Rep: Justin Monturano
Received: 03/17/2025 14:30
Reported: 04/02/2025 12:52

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WS4-WC-HALL3L Lims Reference ID: AD13604-81 Matrix: Drinking Water Sampled: 03/16/25 11:05:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 19:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-WC-HALL3R Lims Reference ID: AD13604-82 Matrix: Drinking Water Sampled: 03/16/25 11:05:00									
Metals									
Lead	ND		1	1.00	µg/L	03/20/25 14:37	03/24/25 19:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WS4-BF-HALL3 Lims Reference ID: AD13604-83 Matrix: Drinking Water Sampled: 03/16/25 11:06:00									
Metals									
Lead	ND		1	1.00	µg/L	03/21/25 10:01	03/24/25 16:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Winslow LIW-School #4

Customer PO: 25-1057
EMSL Sales Rep: Justin Monturano
Received: 03/17/2025 14:30
Reported: 04/02/2025 12:52

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012513604
LIMS Reference ID: AD13604
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Winslow LIW-School #4

Customer PO: 25-1057
EMSL Sales Rep: Justin Monturano
Received: 03/17/2025 14:30
Reported: 04/02/2025 12:52

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13604

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077

PHONE: 1-800-220-3675

FAX: (856) 786-5974

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC			
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts			
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road			
City: Pittsgrove	State/Province: NJ	Zip/Postal Code: 08318	City: Pittsgrove	State/Province: NJ	Zip/Postal Code: 08318		
Phone : 856-205-1077	Fax :		Phone: 856-205-1077	Fax:			
Project Name: Winslow LTW School #4			Email Results To: jeberts@epicenviro.com / teberts@epicenviro.com			Purchase Order: 25-1057	
U.S. State where Samples Collected: NJ			Number of Samples in Shipment: 83			Date of Shipment: 3/17/25	
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):							
Samples Collected by: EMSL ☐ Client ☒ check one			Sampled By (Signature): Casey Lyons			Samples Received Chilled (Y/N)	
Standard Turnaround Time: ☒ 2 Weeks			The following TATs are subject to lab approval ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day				
Failure to complete will hinder processing of samples			Matrix	Preservative	List Test(s) Needed		
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8	Comments
1 BWS4 -FB	☐	☒	3/16/25 N/A	W	2	X	Field Blank
2 WSH-SO-KIT1L	☐	☒	0933	W		X	
3 ↓ (Flush)	☐	☒	0934	W		X	Flush
4 WSH-SO-KIT1R	☐	☒	0933	W		X	
5 ↓ (Flush)	☐	☒	0934	W		X	Flush
Released By (Signature)		Date & Time		Received By		Date & Time	
Casey Lyons		3/17/2025		J. Monnelly (WJ)		3/17/25 1430	
Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other _____							
Instructions or Comments:				Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.			
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb							

Rec'd Pro's.

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13604

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8					Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time
6 WS4-SO-KIT2	☐	☐	3/16/25 0933	W	2										
7 ↓ (Flush)	☐	☐	0934	W											Flush
8 WS4-WC-HALL1FL	☐	☐	0936	W											
9 WS4-WC-HALL1CL	☐	☒	0936	W											
10 WS4-WC-HALL1CR	☐	☒	0937	W											
11 WS4-WC-HALL1FR	☐	☒	0937	W											
12 WS4-WC-MAIN	☐	☒	0938	W											
13 WS4-SO-O1	☐	☒	0939	W											
14 ↓ (Flush)	☐	☒	0940	W											Flush
15 WS4-SO-FAC	☐	☒	0941	W											
16 ↓ (Flush)	☐	☒	0942	W											Flush
17 WS4-SO-NURSE	☐	☒	0944	W											
18 ↓ (Flush)	☐	☒	0945	W											Flush
19 WS4-DW-O8	☐	☒	0946	W											
20 ↓ (Flush)	☐	☒	0947	W											Flush
21 WS4-DW-O2	☐	☒	0948	W											
22 ↓ (Flush)	☐	☒	↓ 0949	W	↓										Flush

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13604

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8					Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time
23 WSH-DW-07	☐	☐	3/16/25 0950	W	2										
24 ↓ (Flush)	☐	☐	0951	W											Flush
25 WSH-DW-03	☐	☐	0952	W											
26 ↓ (Flush)	☐	☒	0953	W											Flush
27 WSH-DW-06	☐	☒	0954	W											
28 ↓ (Flush)	☐	☒	0955	W											Flush
29 WSH-DW-04	☐	☒	0956	W											
30 ↓ (Flush)	☐	☒	0957	W											Flush
31 WSH-DW-05	☐	☒	0958	W											
32 ↓ (Flush)	☐	☒	0959	W											Flush
33 WSH-DW-09	☐	☒	1000	W											
34 ↓ (Flush)	☐	☒	1001	W											Flush
35 WSH-WC-HALL2FR	☐	☒	1003	W											
36 WSH-WC-HALL2ER	☐	☒	1004	W											
37 WSH-WC-HALL2CL	☐	☒	1004	W											
38 WSH-WC-HALL2FL	☐	☒	1004	W											
39 WSH-DW-10	☐	☒	↓ 1005	W	↓										

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13004

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
40 WS4-DW-10 (Flush)	☐	☐	3/16/25 1006	W	2									Flush
41 WS4-DW-19	☐	☐	1007	W										
42 ↓ (Flush)	☐	☐	1008	W										Flush
43 WS4-DW-18	☐	☒	1009	W										
44 ↓ (Flush)	☐	☒	1010	W										Flush
45 WS4-DW-12	☐	☒	1012	W										
46 ↓ (Flush)	☐	☒	1013	W										Flush
47 WS4-DW-16	☐	☒	1015	W										
48 ↓ (Flush)	☐	☒	1016	W										Flush
49 WS4-DW-13	☐	☒	1017	W										
50 ↓ (Flush)	☐	☒	1018	W										Flush
51 WS4-DW-14	☐	☒	1020	W										
52 ↓ (Flush)	☐	☒	1021	W										Flush
53 WS4-DW-15	☐	☒	1023	W										
54 ↓ (Flush)	☐	☒	1024	W										Flush
55 WS4-DW-120	☐	☒	1026	W										
56 ↓ (Flush)	☐	☒	↓ 1027	W	↓									Flush

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13604

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8					Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time
57 WS4-DW-118	☐	☐	3/16/25 1028	W	2										
58 ↓ (Flush)	☐	☐	1029	W											Flush
59 WS4-DW-119	☐	☐	1031	W											
60 ↓ (Flush)	☐	☒	1032	W											Flush
61 WS4-DW-117	☐	☒	1034	W											
62 ↓ (Flush)	☐	☒	1035	W											Flush
63 WS4-SO-WORK	☐	☒	1037	W											
64 ↓ (Flush)	☐	☒	1038	W											Flush
65 WS4-DW-113	☐	☒	1040	W											
66 ↓ (Flush)	☐	☒	1041	W											Flush
67 WS4-DW-110	☐	☒	1043	W											
68 ↓ (Flush)	☐	☒	1044	W											Flush
69 WS4-DW-112	☐	☒	1046	W											
70 ↓ (Flush)	☐	☒	1047	W											Flush
71 WS4-DW-111	☐	☒	1049	W											
72 ↓ (Flush)	☐	☒	1050	W											Flush
73 WS4-DW-109	☐	☒	↓ 1052	W	↓										

(Lab) Received Temperature: _____ °C



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD13604

PHONE:

FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed								Comments
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8				Field pH	Field pH Test Time	Field Temp Deg C	Field Temp Test Time	
74 WS4-DW-109 (Flush)	☐	☐	3/16/25 1053	W	2									Flush
75 WS4-DW-107	☐	☐	1055	W										
76 ↓ (Flush)	☐	☐	1056	W										Flush
77 WS4-SO-108	☐	☒	1058	W										
78 ↓ (Flush)	☐	☒	1059	W										Flush
79 WS4-DW-106	☐	☒	1101	W										
80 ↓ (Flush)	☐	☒	1102	W										Flush
81 WS4-WC-HALL3L	☐	☒	1105	W										
82 WS4-WC-HALL3R	☐	☒	1105	W										
83 WS4-BF-HALL3	☐	☒	1106	W										
_____	☐	☒	_____	W	_____									_____
	☐	☒		W										
	☐	☒		W										
	☐	☒		W										
	☐	☒		W										
	☐	☒		W										
	☐	☒		W										

(Lab) Received Temperature: _____ °C